

Pursuant to the authority vested in the Air Resources Board by Health and Safety Code Division 26, Part 5, Chapter 2; and pursuant to the authority vested in the undersigned by Health and Safety Code Sections 39515 and 39516 and Executive Order G-14-012;

**IT IS ORDERED AND RESOLVED:** The engine and emission control systems produced by the manufacturer are certified as described below for use in on-road motor vehicles with a manufacturer's GVWR over 14,000 pounds. Production engines shall be in all material respects the same as those for which certification is granted.

MODEL YEAR	ENGINE FAMILY	ENGINE SIZES (L)	FUEL TYPE <sup>1</sup>		STANDARDS & TEST PROCEDURE	INTENDED SERVICE CLASS <sup>2</sup>	ECS & SPECIAL FEATURES <sup>3</sup>		DIAGNOSTIC <sup>6</sup>
			Compressed Natural Gas				TURBINE ECM		
2014	ECSTH0.31CNG	0.31 KG/S			Diesel – special cycle	UB-Hybrid			EMD
PRIMARY ENGINE'S IDLE EMISSIONS CONTROL <sup>5</sup>		ADDITIONAL IDLE EMISSIONS CONTROL <sup>5</sup>							
EXEMPT		N/A							
ENGINE (L)	ENGINE MODELS / CODES (rated power, in hp)								
0.31 KG/S	See attachment for engine models and ratings								
*	*								
<sup>*</sup> =not applicable; GVWR=gross vehicle weight rating; 13 CCR xyz=Title 13, California Code of Regulations, Section xyz; 40 CFR 86.abc=Title 40, Code of Federal Regulations, Section 86.abc; L=liter; hp=horsepower; kw=kilowatt; hr=hour; <sup>1</sup> CNG/LNG=compressed/liquefied natural gas; LPG=liquefied petroleum gas; E85=85% ethanol fuel; MF=multi fuel a.k.a. BF=bi fuel; DF=dual fuel; FF=flexible fuel; <sup>2</sup> L/M/H HDD=light/medium/heavy heavy-duty diesel; UB=urban bus; HDO=heavy duty Otto; <sup>3</sup> ECS=emission control system; TWC/OC=three-way/oxidizing catalyst; NAC=NOx adsorption catalyst; SCR-U / SCR-N=selective catalytic reduction – urea / – ammonia; WU (prefix) =warm-up catalyst; DPF=diesel particulate filter; PTOX=periodic trap oxidizer; HO2S/O2S=heated/oxygen sensor; HAFS/AFS=heated/air-fuel-ratio sensor (a.k.a., universal or linear oxygen sensor); TBI=throttle body fuel injection; SFI/MFI=sequential/multi port fuel injection; DGI=direct gasoline injection; GCARB=gaseous carburetor; IDI/DDI=indirect/direct diesel injection; TC/SC=turbo/super charger; CAC=charge air cooler; EGR / EGR-C=exhaust gas recirculation / cooled EGR; PAIR/AIR=pulsed/secondary air injection; SPL=smoke puff limiter; ECM/PCM=engine/powertrain control module; EM=engine modification; 2 (prefix)=parallel; (2) (suffix)=in series; <sup>5</sup> ESS=engine shutdown system (per 13 CCR 1956.8(a)(6)(A)(1); 30g=30 g/hr NOx (per 13 CCR 1956.8(a)(6)(C); APS =internal combustion auxiliary power system; ALT=alternative method (per 13 CCR 1956.8(a)(6)(D); Exempt=exempted per 13 CCR 1956.8(a)(6)(B) or for CNG/LNG fuel systems; N/A=not applicable (e.g., Otto engines and vehicles); <sup>6</sup> EMD=engine manufacturer diagnostic system (13 CCR 1971); OBD=on-board diagnostic system (13 CCR 1971.1);									

Following are: 1) the FTP exhaust emission standards, or family emission limit(s) as applicable, under 13 CCR 1956.8; 2) the SET and NTE limits under the applicable California exhaust emission standards and test procedures for heavy-duty diesel engines and vehicles (Test Procedures); and 3) the corresponding certification levels, for this engine family. "Diesel" CO, SET and NTE certification compliance may have been demonstrated by the manufacturer as provided under the applicable Test Procedures in lieu of testing. (For flexible- and dual-fueled engines, the CERT values in brackets [ ] are those when tested on conventional test fuel. For multi-fueled engines, the STD and CERT values for default operation permitted in 13 CCR 1956.8 are in parentheses.)<sup>4</sup>


in g/bhp-hr	NMHC		NOx		NMHC+NOx		CO		PM		HCHO	
	FTP	SET	FTP	SET	FTP	SET	FTP	SET	FTP	SET	FTP	SET
STD	0.14	0.14	0.20	0.20	*	*	15.5	15.5	0.01	0.01	*	*
CERT	0.08	0.10	0.05	0.05	*	*	0.2	0.5	0.002	0.002	*	*
NTE	0.21		0.30		*		19.4		0.02		*	

<sup>4</sup> g/bhp-hr=grams per brake horsepower-hour; FTP=Federal Test Procedure; EURO=Euro III European Steady-State Cycle, including RMCSET=ram mode cycle supplemental emissions testing; NTE=Not-to-Exceed; STD=standard or emission test cap; FEL=family emission limit; CERT=certification level; NMHC/HC=non-methane/hydrocarbon; NOx=oxides of nitrogen; CO=carbon monoxide; PM=particulate matter; HCHO=formaldehyde; (Rev.: 2007-02-26)

**BE IT FURTHER RESOLVED:** For the listed engine models the manufacturer has submitted the materials to demonstrate certification compliance with 13 CCR 1965 (emission control labels), 13 CCR 1971 (engine manufacturer diagnostic) and 13 CCR 2035 et seq. (emission control warranty).

Engines certified under this Executive Order must conform to all applicable California emission regulations. The Bureau of Automotive Repair will be notified by copy of this Executive Order.

Executed at El Monte, California on this 2 day of May 2014.



Annette Hebert, Chief  
 Emissions Compliance, Automotive Regulations and Science Division

# Engine Model Summary Template

A-338-0011  
4-14-2014

Attachment 1 of 1

Engine Family	1.Engine Code	2.Engine Model	3.BHP@RPM (SAE Gross)	4.Fuel Rate: mm/stroke @ peak HP (for diesels only)	5.Fuel Rate: (lbs/hr) @ peak HP (for diesels only)	6.Torque @ RPM (SEA Gross)	7.Fuel Rate: mm/stroke@peak torque	8.Fuel Rate: (lbs/hr)@peak torque	9.Emission Control Device Per SAE J1930
ECSTH0.31CNG	509880-201	30X-HBx-THxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	509879-201	30Y-HBx-THxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	509880-400	30W-HBx-THxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	509879-400	30Z-HBx-THxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	529759-100	30X-HBx-VHxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	529760-100	30Y-HBx-VHxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	529761-100	30W-HBx-VHxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM
ECSTH0.31CNG	529762-100	30Z-HBx-VHxx	30kW@ 96,000	7217 Btu/min	N/A	N/A	N/A	N/A	MicroTurbine ECM