

**Appendix D**

**Waste Gas Source Test Data**



## Waste Gas Source Test Data

	lb/MW-hr		
	NOx	CO	VOC*
Proposed 2008 Standard	0.5	6.0	1.0
Proposed 2013 Standard	0.07	0.10	0.02

Landfill gas fueled	lb/MW-hr		
	NOx	CO	VOC*
Microturbines			
1	0.20	0.50	0.09
2	0.20	0.10	0.16
3	0.16	0.17	0.19
4	0.14	0.46	0.16
5	0.12	0.37	0.19
6	0.12	0.36	0.14
7	0.09	0.40	0.19
8	0.06	0.06	0.13
Fuel Cells			
1	0.01	0.02	NA
averages	<b>0.12</b>	<b>0.27</b>	<b>0.16</b>

Digester gas fueled	lb/MW-hr		
	NOx	CO	VOC*
Microturbines			
1	0.19	0.13	0.22
2	0.15	3.17	0.12
3	0.08	9.00	0.45
4	0.07	4.67	0.15
Fuel Cells			
1	0.01	0.03	0.70
averages	<b>0.10</b>	<b>3.40</b>	<b>0.33</b>

Oil field waste gas fueled	lb/MW-hr		
	NOx	CO	VOC*
Microturbines			
1	0.20	0.19	0.20
averages	<b>0.20</b>	<b>0.19</b>	<b>0.20</b>

\*VOCs listed as hexane